



3205 US-23 South
Alpena, MI 49707
Ph: 989-356-6375
Fax: 989-354-8286

July 2, 2024

***Scenic Rte #3
Request for Information #2***

This RFI is issued for the purpose of modifying and/or clarifying the original drawings and specifications and shall take precedence over them.

All work included herein shall be in accordance with the original drawings and specifications except as specifically noted herein. All incidental items required to provide the following modifications shall be included even though not specifically described.

It shall be the responsibility of the contractors to notify their subcontractors and/or suppliers of the clarifications, modifications, and/or revisions included herein.

The following project clarifications are provided based on questions received:

1. Frontier Communications has a Fiber Optic line running approximately 18' north of centerline along this project. This line is bored under the crossing area at a depth varying from 7.5' to 12' below grade.

The Fiber line will be in conflict with the sheet piling for this project.

Frontier is planning to relocate this line to the ROW and out of conflict with this project. They plan to have their work completed by the end of August, after which sheet piling can be installed.

The Contractor is reminded that all in-stream work must be completed prior to October 1st as required by the EGLE permit.